

**Furnace/Heating  
Equipment Inspection  
Record**

Address \_\_\_\_\_

Per the requirements of the St. Louis Park Property Maintenance Inspection, please have your heating equipment tested by a current City of St. Louis Park Licensed Mechanical Contractor for the following items:

- 1) Overall inspection of furnace/space heater/boiler including but not limited to venting, hi-lo switch, proper drafting & gas connections, AND
- 2) One of the following tests for determining heat exchanger integrity in warm air furnaces:
  - a) Smoke Bomb Test
  - b) Leak Seek Test
  - c) Het-kit Test

Note: Carbon monoxide testing procedures can vary greatly and only indicates possible spillage or back-drafting. It can be used but in conjunction with the above requirements.

Services Performed

Pass/Fail/Not Applicable

- ✓ \_\_\_\_\_ Heat Exchanger Test (Circle one) a) smoke bomb b) Leak-seek c) Het-kit
- ✓ \_\_\_\_\_ Combustion Chamber: Visual inspection for cracks.
- ✓ \_\_\_\_\_ Chimney & Vent connection: Inspect for deterioration.
- ✓ \_\_\_\_\_ Control System: Check for safe operation of wiring & controls.
- ✓ \_\_\_\_\_ Burners: Check for correct adjustment to minimize carbon monoxide output.
- ✓ \_\_\_\_\_ Combustion Flue: Check for clearances to combustible material.
- ✓ \_\_\_\_\_ Heating Unit(s): Visual inspection for excessive rust, ensuring access doors in place, clearances to combustibles and general overall working condition.
- ✓ \_\_\_\_\_ Attach copy of all repair work/adjustments done.
- ✓ \_\_\_\_\_ Year Manufactured
- ✓ \_\_\_\_\_ Comments \_\_\_\_\_

Date of Testing \_\_\_\_\_

Signature \_\_\_\_\_ SLP License # \_\_\_\_\_

Company \_\_\_\_\_ Phone Number \_\_\_\_\_

*These tests are designed to ensure furnaces and heating appliances are operating safely and properly at the time of City Inspection and can furnish adequate heat to the dwelling.*