



NOTES:

1. ALL VALVES TO BE CLOW RESILIENT WEDGE GATE VALVES.
2. ALL BOLTS TO BE BLUE TEFLON COATED BOLTS.
3. GATE VALVE ADAPTOR SHALL BE 1/4" STEEL WITH PROTECTIVE COATING.
4. CONSTRUCT 3/4" RUBBER GASKET BETWEEN GATE VALVE AND ADAPTOR.
5. "WATER" MUST BE STAMPED ON THE GATE VALVE LID.

GATE VALVE ADAPTOR