



NOTES:

1. FIELD VERIFY BURY DEPTH PRIOR TO ORDERING HYDRANT AND VALVE.
2. EACH HYDRANT MUST INCLUDE A THREADED WEEP HOLE. THE WEEP HOLE SHALL REMAIN OPEN UNLESS GROUNDWATER IS PRESENT OR IF THE HYDRANT IS LOCATED IN A CONTAMINATED AREA.
3. HYDRANT COATINGS DAMAGED DURING CONSTRUCTION SHALL BE REPAIRED AFTER THE BITUMINOUS BASE IS INSTALLED. PRIME AND PAINT HYDRANTS PER AWWA AND MANUFACTURER'S STANDARD.
4. ALL BOLTS MUST BE BLUE TEFLON COATED.
5. HYDRANT RODS MUST BE STAINLESS STEEL.
6. A BURY TAG MUST BE PROVIDED WITH EVERY HYDRANT. LOCATE THE BURY TAG ON TOP OF THE BONNET.